



## CROSS-SECTION

### NOTES:

1. Tree species and caliper size are to be approved by the City Arborist.
2. Adjust planting locations so that tree crown or root ball does not conflict with above or below - ground utilities.
3. Do not undermine curb or sidewalk when excavating.
4. An 18-inch deep root barrier shall be added where required by the City Arborist.
5. Opposite tree stakes, provide two, 3-inch diameter ADS perforated pipe watering troughs, filled with pea gravel.
6. Provide a loop in chain lock or guy hose large enough to allow for trunk growth.
7. Tree stakes are to be removed following the required establishment period.



City Of Beaverton

## ENGINEERING DEPARTMENT

CITY ENGINEER  
Terry Waldele, P.E.

6 - 10 - 04  
5 - 15 - 02

## STANDARD SIDEWALK TREETWELL

DRAWN BY  
JR - CPD

DRAWING NO.  
240